## Conductoare din otel-zincat, conform ASTM A 363-1972
## *Steel Stranded Conductors, according to ASTM A 363-1972*

| Diametru nominal conductor *Nominal conductor diameter* mm | Sectiune calculata *Calculated section* $mm^2$ | Numar sarme *No. of wires* | Diametru sarma *Wire diameter* mm | Masa *Weight* kg/km | Forta de rupere Breaking Load | | |
|---|---|---|---|---|---|---|---|
| | | | | | Grad *Grade* High Strength N | Grad *Grade* Extra High Strength N | Grad *Grade* Utilities N |
| 7.94 | 31.90 | 3 | 3.68 | 255 | - | - | 28900 |
| 7.94 | 38.31 | 7 | 2.64 | 305 | 35600 | 49800 | - |
| 9.52 | 51.14 | 7 | 3.05 | 407 | 48000 | 68400 | 51200 |
| 11.11 | 74.45 | 7 | 3.68 | 595 | 64500 | 92500 | - |
| 12.70 | 96.51 | 7 | 4.19 | 770 | 83600 | 119600 | - |